

místnost	S _i => S	p _{ni}	p _{ni} ·S _i	a _{ni}	p _{ni} ·a _{ni} ·S _i	p _{si}	p _{si} ·S _i	otvor	počet	šířka	h _{oi}	S _{oi} => S _o	S _{oi} ·h _{oi}	h _o	h _s	h _s ·S _i	n	k	b _{iskut}	b _i	b _i ·S _i	a _n	a _s	p _n	p _s	p	a	b	c	p _v	SPB	z _{max}	d _{max}	ξ _{max}		
	m ²	kg.m ⁻²	kg	-	kg	kg.m ⁻²	kg		ks	m	m	m ²	m ³	m	m	m ³	-	m ^{-1/2}	-	-	m ²	-	-	kg.m ⁻²	kg.m ⁻²	kg.m ⁻²	-	-	-	kg.m ⁻²	-	ks	m	m		
Dřevěná pergola	52,955																									26,43	0,93	0,50	1,00	12,24	--	I	7	55,08	38,51	
Pergola	44,8	20	895,6	0,9	806,04	4,89	218,97	1. otvor	1	2,00	2,00	4,00	8,00	2,30	2,45	#####	0,338	0,259	0,489	0,500	22,390															
								2. otvor	2	2,43	2,40	11,64	27,94																							
								3. otvor	0	1,00	1,00	0,00	0,00																							
								4. otvor	0	1,00	1,00	0,00	0,00																							
								5. otvor	0	1,00	1,00	0,00	0,00																							
												15,64	35,94																							
								1. otvor	1	2,40	2,40	5,76	13,82																							
								2. otvor	0	2,38	1,50	0,00	0,00																							
								3. otvor	0	1,00	1,00	0,00	0,00																							
								4. otvor	0	1,00	1,00	0,00	0,00																							
								5. otvor	0	1,00	1,00	0,00	0,00																							
Kolárna	8,2	30	245,25	1,05	257,5125	4,89	39,976					5,76	13,82	2,40	2,45	20,03	0,697	0,226	0,207	0,500	4,088															
Σ	53,0		1140,9		1063,5525		258,95							2,45	#####						26,478			0,93												

z ks h_y pro mr m h_y pro c m S pro c ☐ podzemní podlaží NEPRAVDA
 1 0 0 1 0 zadej úroveň hp 1

Součinitel c:

☐ EPS $c_1 = 0,7$ 1 NEPRAVDA
☐ SSHZ $c_3 = 0,5$ LH 1 NEPRAVDA

☒ SHZ 0,5 1
☒ k dispozici pouze jedna ÚC pro 10% a více osob 1,00 12,24 2,00 I 7 55,08 38,51